

Certificate of constancy of performance,

0832-CPR-F0912

In compliance with Regulation 305/2011/EU of the European Parliament and of the council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Taktis
2 to 8 Loop Analogue Addressable Control and Indicating Equipment
(For full product details and conditions of use refer to appendix)

Produced by or for

Kentec Electronics Ltd

**Units 25-27, Fawkes Avenue
Questor, Dartford
Kent
DA1 1JQ
United Kingdom**

and produced in the manufacturing plant(s)

Kentec Electronics Ltd

**Units 25-27, Fawkes Avenue
Questor, Dartford
Kent
DA1 1JQ
United Kingdom**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 54-2: 1997 + A1: 2006
EN 54-4:1997 + A1: 2002 + A2: 2006

under system 1 are applied and that

the product fulfils all the prescribed requirements set out above.

This certificate was first issued on 05 February 2015 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.



M McCullagh, Certification Manager
On behalf of BRE Global Limited
Date of issue: 05 February 2015
Issue number: 01

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email enquiries@breglobal.com.

Appendix to Certificate of constancy of performance 0832-CPR- F0912

Incorporating the following units:

- S721 LCD Main Processor Board
- S722 Main Back Board
- S2008 Taktis Network, Ethernet & IFAM Interface Module
- S758 Dual loop Module
- S769 System Board A module
- S770 System Board B Module
- S771 Zone LED Board
- S787 Taktis Vision Unit
- S768 Taktis Thermal Printer Assembly
- S406 5.25 Amp Power Supply Unit
- S408 10.25 Amp Power Supply Unit (optional)

Certified with the following Options with requirements from EN 54-2:1997

- 7.8 Output to fire alarm device(s)
- 7.9.1 Output to fire alarm routing equipment
- 7.9.2 Alarm confirmation input from fire alarm routing equipment
- 7.10.3 Output to type C
- 7.10.4 Fault monitoring of fire protection equipment
- 7.11 Delay to outputs
- 7.12.1 Dependencies on more than one alarm signal – Type A
- 7.12.2 Dependencies on more than one alarm signal – Type B
- 7.12.3 Dependencies on more than one alarm signal – Type C
- 7.13 Alarm counter
- 8.3 Fault signals from points
- 8.9 Output to fault warning routing equipment
- 9.5 Disablement of addressable points
- 10 Test condition

Note:

1. Scope of approval does not include the operation of the network functionality.
2. This approval does not constitute compliance with the fire detection and alarm systems requirements of EN 54-13.



M McCullagh, Certification Manager
On behalf of BRE Global Limited
Date of issue: 05 February 2015
Issue number: 01

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email enquiries@breglobal.com.