

Declaration of Performance

According to Construction Products Regulation EU N° 305/2011



Certificate Reference N° 00007

Product identification:

FIRE ALARM POWER SUPPLY EQUIPMENT

Type:

K25250 and KD25250 series

Intended use:

Fire detection and fire alarm systems installed in and around buildings

Manufacturer:

Kentec Electronics Limited
Units 25-27 Fawkes Avenue
Questor
Dartford
Kent
DA1 1JQ
UK

Authorised representative:

Not applicable

System of assessment and verification of constancy of performance.

System 1

BSI

Performed type testing and the initial inspection of the manufacturing plant and of factory production control with continuous surveillance, assessment and approval of the factory production control under system 1 and issued following certificate of constancy of performance:

2797 CPR 553773

All requirements including all Essential Characteristics and the corresponding performances for the intended use or uses have been determined as described in the hEN mentioned in the table below.

Essential characteristics	Performance	Harmonized technical specification
Operational reliability	Passed	EN 54-4:1997 + A2:2006 Art.: 4, 5, 6, 7 and 8
Durability of operational reliability, Temperature resistance	Passed	EN 54-4:1997 + A2:2006 Art.: 9.5
Durability of operational reliability, Vibration resistance	Passed	EN 54-4:1997 + A2:2006 Art.: 9.7, 9.8 and 9.15
Durability of operational reliability, Electrical stability	Passed	EN 54-4:1997 + A2:2006 Art.: 9.9 to 9.13
Performance of power supply	Passed	EN 54-4:1997 + A2:2006 Art.: 4, 5, 6
Durability of operational reliability, humidity resistance	Passed	EN 54-4:1997 + A2:2006 Art.: 9.6, 9.14

The performance of the product identified above is in conformity with the set of declared performance/s.

This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:



Ray Turner

Compliance Director

Dartford

04/12/2019

Declaration of Performance

According to Construction Products Regulation EU N° 305/2011



Certificate Reference N° 00006

Product identification:

FIRE ALARM POWER SUPPLY EQUIPMENT

Type:

K25400 and KD25400 series

Intended use:

Fire detection and fire alarm systems installed in and around buildings

Manufacturer:

Kentec Electronics Limited
Units 25-27 Fawkes Avenue
Questor
Dartford
Kent
DA1 1JQ
UK

Authorised representative:

Not applicable

System of assessment and verification of constancy of performance.

System 1

BSI

Performed type testing and the initial inspection of the manufacturing plant and of factory production control with continuous surveillance, assessment and approval of the factory production control under system 1 and issued following certificate of constancy of performance:

2797 CPR 553773

All requirements including all Essential Characteristics and the corresponding performances for the intended use or uses have been determined as described in the hEN mentioned in the table below.

Essential characteristics	Performance	Harmonized technical specification
Operational reliability	Passed	EN 54-4:1997 + A2:2006 Art.: 4, 5, 6, 7 and 8
Durability of operational reliability, Temperature resistance	Passed	EN 54-4:1997 + A2:2006 Art.: 9.5
Durability of operational reliability, Vibration resistance	Passed	EN 54-4:1997 + A2:2006 Art.: 9.7, 9.8 and 9.15
Durability of operational reliability, Electrical stability	Passed	EN 54-4:1997 + A2:2006 Art.: 9.9 to 9.13
Performance of power supply	Passed	EN 54-4:1997 + A2:2006 Art.: 4, 5, 6
Durability of operational reliability, humidity resistance	Passed	EN 54-4:1997 + A2:2006 Art.: 9.6, 9.14

The performance of the product identified above is in conformity with the set of declared performance/s.

This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:



Ray Turner

Compliance Director

Dartford

04/12/2019