




## Certificate of Compatibility

We are pleased to confirm that



**Kentec Electronics Ltd**

Syncro AS - Analogue Addressable Fire Alarm Control Panel

Type - EN54  
Software Version - 5.23 UK

has been tested and approved for use with  
XPlorer<sup>®</sup>, XP95<sup>®</sup> and Discovery<sup>®</sup> digital communications protocols  
and devices in accordance with Apollo test schedule TSP 01


Observations are listed in Appendix A attached


**Project no:** TSE 243

**Certificate no:** 132

**Issued on:** 23<sup>rd</sup> January 2009

**Signed:**

  
S. Flavell, Technical Sales Supervisor

  
P. Smith, Marketing Director



## Certificate of Compatibility – Appendix A

**The following XP95 feature is not supported:**

Group Address

**The following Discovery feature is not supported:**

Drift Compensation Value

(viewable)

User Bytes (E<sup>2</sup> location 11)

User Bytes (E<sup>2</sup> location 12)

User Bytes (E<sup>2</sup> location 13)

User Bytes (E<sup>2</sup> location 14)

Month of Manufacture (viewable)

Approval Code

Conventional Alarm Facility

**Project no:** TSE 243

**Certificate no:** 131 - 133