

Certificate of Compliance

Certificate Number **20110628-S8485B**
Report Reference **S8485, 2011 May 30**
Issue Date **2011 June 28**

Page 1 of 1



Issued to: KENTEC ELECTRONICS LTD

VES FIRE DETECTION SYSTEMS
FAWKES AVE, UNITS 25-27, DARTFORD TRADE
DARTFORD, KENT
DA1 1JQ UNITED KINGDOM

*This is to certify that
representative samples of*

CONTROL UNITS, SYSTEM


Fire Alarm Equipment:
Releasing Panel – Elite XT Panel Series, Models VF1810-10, -11, -40, -41,
K1810-12, -13, -43, -44.

*Have been investigated by Underwriters Laboratories Inc.® (UL) or any authorized
licensee of UL in accordance with the Standard(s) indicated on this Certificate.*

Standard(s) for Safety: UL864, Control Units and Accessories for Fire Alarm Systems, Ninth Edition

Additional Information: See UL On-Line Certification Directory at www.UL.com for additional information.

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

William R. Carney

Director, North American Certification Programs

Underwriters Laboratories Inc.

Any information and documentation involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://www.ul.com/global/eng/pages/corporate/contactus/>

Certificate of Compliance

Certificate Number **20110628-S8485A**
Report Reference **S8485, 2011 May 31**
Issue Date **2011 June 28**

Page 1 of 2



Issued to: KENTEC ELECTRONICS LTD

VES FIRE DETECTION SYSTEMS
FAWKES AVE, UNITS 25-27, DARTFORD TRADE
DARTFORD, KENT
DA1 1JQ UNITED KINGDOM

*This is to certify that
representative samples of*


CONTROL UNIT ACCESSORIES, SYSTEM
See Addendum Page

Have been investigated by Underwriters Laboratories Inc.® (UL) or any authorized licensee of UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL864, Control Units and Accessories for Fire Alarm Systems, Ninth Edition

Additional Information: See UL On-Line Certification Directory at www.UL.com for additional information.

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

William R. Carney

Director, North American Certification Programs

Underwriters Laboratories Inc.

Any information and documentation involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://www.ul.com/global/eng/pages/corporate/contactus/>

Certificate of Compliance

Certificate Number **20110628-S8485A**
Report Reference **S8485, 2011 May 31**
Issue Date **2011 June 28**

Page 2 of 2



This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Fire Alarm Equipment:

Lamp Status Units, Models VF1821-11, -12, -13, -14, -41, -42, -43, -44, K1821-11, -12, -13, -14, -41, -42, -43, -44.

Ancillary Board w/Enclosure, Models VF1822-10, -40, K1822-10, -40.

Abort Switches, Models VF1823-10, -40, K1823-10, -40.

End-of-Line Devices, Part Nos. VF1895-00, VF1896-00, VF1897-00, VF1898-00, VF1899-00.

William R. Carney

Director, North American Certification Programs

Underwriters Laboratories Inc.

Any information and documentation involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://www.ul.com/global/eng/pages/corporate/contactus/>