

# Certificate of Constancy of Performance

This is to certify that:


Kentec Electronics Limited  
Unit 25-26  
Fawkes Avenue Questor  
Dartford  
DA1 1JQ  
United Kingdom

Holds Certificate Number: 2797 CPR 553773

In respect of:

**EN 54-4:1997/A2:2006 - Fire detection and fire alarm systems - Part 4: Power supply equipment.**

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the above construction product. This certificate attests that all the provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the above standard(s) under system 1 are applied and that the product fulfils (products fulfil) all the prescribed requirements set out above. This certificate remains valid as long as the test methods and/or factory production control requirements included in the harmonised standard(s), used to assess the performance of the declared essential characteristics, do not change and the products(s), and the manufacturing conditions in the plants(s) are not modified significantly.



For and on behalf of BSI, a Notified Body for the above Regulation (Notified Body Number 2797):

Previous Notified Body: BSI 0086

First Issued: 2010-07-30

\_\_\_\_\_  
Drs. Dave Hagenaaars, Managing Director

Latest Issue: 2019-03-26

Page: 1 of 3

...making excellence a habit.™

# Certificate of Constancy of Performance

No. 2797 CPR 553773

EN 54-4:1997/A2:2006 - Fire detection and fire alarm systems - Part 4: Power supply equipment.

## Product Information

Model Reference	Type
K2540003	4A Standalone Power Supply Equipment suitable for use with up to 12Ah batteries without dual power output board
K25400M3	4A Standalone Power Supply Equipment suitable for use with up to 17.2Ah batteries without dual power output board
K2540015	4A Standalone Power Supply Equipment suitable for use with up to 26Ah batteries without dual power output board
K25250M2	2.5A Standalone Power Supply Equipment suitable for use with up to 7Ah batteries without dual power output board
K2525003	2.5A Standalone Power Supply Equipment suitable for use with up to 12Ah batteries without dual power output board
K25250M3	2.5A Standalone Power Supply Equipment suitable for use with up to 17.2Ah batteries without dual power output board
KD2540003	4A Standalone Power Supply Equipment suitable for use with up to 12Ah batteries with dual power output board
KD25400M3	4A Standalone Power Supply Equipment suitable for use with up to 17.2Ah batteries with dual power output board
KD2540015	4A Standalone Power Supply Equipment suitable for use with up to 26Ah batteries with dual power output board
KD25250M2	2.5A Standalone Power Supply Equipment suitable for use with up to 7Ah batteries with dual power output board
KD2525003	2.5A Standalone Power Supply Equipment suitable for use with up to 12Ah batteries with dual power output board
KD25250M3	2.5A Standalone Power Supply Equipment suitable for use with up to 17.2Ah batteries with dual power output board

Note: This series of power supply equipment operate from a mains input of 230V AC or 110V AC link selectable.

First Issued: 2010-07-30

Latest Issue: 2019-03-26

Page: 2 of 3

This certificate has been issued by and remains the property of BSI Group The Netherlands B.V., John M. Keynesplein 9, 1066 EP Amsterdam, The Netherlands and should be returned immediately upon request.  
To check its validity telephone +31 20 3460780. An electronic certificate can be authenticated [online](#).

BSI Group The Netherlands B.V., registered in the Netherlands under number 33264284, at John M. Keynesplein 9, 1066 EP Amsterdam, The Netherlands  
A member of BSI Group of Companies.

# Certificate of Constancy of Performance

No. 2797 CPR 553773

## Manufacturing Plant

Kentec Electronics Limited  
Unit 25-26  
Fawkes Avenue Questor  
Dartford  
DA1 1JQ  
United Kingdom

## Certified Activities

EN 54-4:1997/A2:2006 - Fire detection and fire alarm systems - Part 4: Power supply equipment.



First Issued: 2010-07-30

Latest Issue: 2019-03-26

Page: 3 of 3

This certificate has been issued by and remains the property of BSI Group The Netherlands B.V., John M. Keynesplein 9, 1066 EP Amsterdam, The Netherlands and should be returned immediately upon request.  
To check its validity telephone +31 20 3460780. An electronic certificate can be authenticated [online](#).

BSI Group The Netherlands B.V., registered in the Netherlands under number 33264284, at John M. Keynesplein 9, 1066 EP Amsterdam, The Netherlands  
A member of BSI Group of Companies.