

## **BRE Global Ireland**

**Notified Body No. 2831** 

BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

# **Certificate of constancy of performance** 2831-CPR-F4391

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

#### **ARF-WL8-IN Wireless Single Input Module**

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade and mark of:

ASI Oy Ltd (Argus Spectrum International)

Laitaatsillantie 3 Savonlinna 57170

Finland

and produced in the manufacturing plant(s):

ASI Oy Ltd (Argus Spectrum International)

Laitaatsillantie 3 Savonlinna

57170 Finland

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-18:2005 - Input/output devices EN 54-25:2008 - Components using radio links

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

## the constancy of performance of the construction product.

This certificate was first issued on 26 June 2020 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Date of First Issue: 26 June 2020

P Halligan, Certification Engineer Date of Issue: 21 December 2021

On behalf of BRE Global Assurance (Ireland) Limited Issue number 02

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie

BF1938i Rev.1.0 Page 1 of 2 © BRE Global Assurance (Ireland) Limited, 2021



### **BRE Global Ireland**

Notified Body No. 2831

BRE Global Assurance (Ireland) Limited DCU Alpha, Old Finglas Road Glasnevin, Dublin, D11 KXN4 Ireland

T: +353 (0) 18824344 E: enquiries@breglobalireland.ie www.breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F4391

**ARF-WL8-IN Wireless Single Input Module** 

Variants:

EK-WL8-IN – (EKHO Brand) KM-WL8-IN – (K-Mesh Brand)

Note:

1. The device must be used with the following batteries only:

- Primary - CR123A (3V)

- Secondary - CR2032 (3V)

Date of First Issue: 26 June 2020

P Halligan, Certification Engineer, Date of issue: 21 December 2021

On behalf of BRE Global Assurance (Ireland) Limited Issue number: 02

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie

BF1938i Rev.1.0 Page 2 of 2 © BRE Global Assurance (Ireland) Limited, 2021