LPCB®

www.redbooklive.com

Certificate of Product Approval

Certificate Number: 164h-(cl-3) Issue: 01

Kentec Electronics Limited

Units 25-26
Fawkes Ave
Questor
Dartford, Kent
DA1 1JQ
United Kingdom

is certified by BRE Global Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

Alarm Warning Devices
KS-BSND
KS-WSND2-RED
KS-BSND2
(refer to Appendix for details)

Standards

EN 54-3:2001 + A1:2002 + A2:2006

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for BRE Global Ltd	Verifier	Date of Issue	Date of First Issue
P. Halligan	P Halligan	29 September 2022	29 September 2022

This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.

© BRE Global Ltd, 2022

80018

LPCB®

Appendix to Certificate No: 164h-(cl-3) Issue: 01

Kentec Electronics Limited

Certified Product	Description	LPCB Ref.No.
KS-BSND	Intelligent Analogue Addressable Type A Base Sounder – White Version (KS-BASE-3T base) Note: 1. Meets the requirements of EN 54-3 for tones 1 to 51 listed under Approved Tones.	164h/01
KS-WSND2-RED	Intelligent Analogue Addressable Type A Wall Sounder (KS-BASE-3T-SCI, KS-BASE-WS-RED bases) Note: 1. Meets the requirements of EN 54-3 for tones 1 to 51 listed under Approved Tones.	164h/02
KS-BSND2	Intelligent Analogue Addressable Type A Base Sounder - White Version (KS BASE-4T base) Note: 1. Meets the requirements of EN 54-3 for all 56 tones	164h/06

Approved Tones

1 – 925 Hz : 250 ms / 628 Hz : 250 ms
2 – 925 Hz Continuous
3 – 628 Hz Continuous
4 – (French) 554 Hz : 100 ms / 440 Hz : 400 ms
5 – (Swedish) 660 Hz : 150 ms / Off : 150 ms
6 – 925 Hz : 150 ms / Off : 600 ms
7 – 670 Hz : 250 ms / 845 Hz : 370 ms
8 – Whoop 500 Hz – 1200 Hz : 3000 ms / Off : 500 ms
9 – 1200 Hz : 500 ms / 500 Hz : 500 ms
10 – 970 Hz : 500 ms / Off : 500 ms
11 – Sweep 800 Hz – 970 Hz over 140 ms (7 Hz)
12 – Sweep 800 Hz – 970 Hz over 1000 ms (1 Hz)
13 – Sweep 800 Hz – 970 Hz over 20 ms (50 Hz)
14 – Sweep 2400 Hz – 2850 Hz over 140 ms (7 Hz)
15 – Sweep 2400 Hz – 2850 Hz over 1000 ms (1 Hz)

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for BRE Global Ltd	Verifier	Date of Issue	Date of First Issue
P. Halligan	P Halligan	29 September 2022	29 September 2022

This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.

 © BRE Global Ltd, 2022

80018

LPCB®

Appendix to Certificate No: 164h-(cl-3) Issue: 01

Kentec Electronics Limited

16 – Sweep 300 Hz – 1200 Hz over 1000 ms (1 Hz)
17 – ISO8201 : 970 Hz : 500 ms / Off : 500 ms
18 – ISO8201 : 2850 Hz : 500 ms / Off : 500 ms
19 – 800 Hz : 250 ms / 970 Hz : 250 ms
20 – 2850 Hz Continuous
21 - 2400 Hz : 250 ms / 2850 Hz : 250 ms
22 - 800 Hz : 500 ms / 970 Hz : 500 ms
23 - 2850 Hz : 500 ms / Off : 500 ms
24 - 925 Hz : 250 ms / Off : 1000 ms
25 - 970 Hz Continuous
26 - 660 Hz : 1800 ms / Off: 1800 ms
27 - 660 Hz : 6500 ms / Off : 13000 ms
28 - 660 Hz Continuous
29 - 554 Hz : 500 ms / 440 Hz : 500 ms
30 - 660 Hz : 500 ms / Off : 500 ms
31 - 2850 Hz : 150 ms / Off : 100 ms
32 - Sweep 2400 Hz - 2850 Hz over 20 ms (50 Hz)
33 - Sweep 800 Hz - 970 Hz over 500 ms (2 Hz)
34 - 988 Hz : 250 ms / 645 Hz : 250 ms
35 - 510 Hz : 250 ms / 610 Hz : 250 ms
36 - Sweep 800 Hz - 970 Hz over 110 ms (9 Hz)
37 - Sweep 800 Hz - 970 Hz over 330 ms (3 Hz)
38 - 845 Hz Continuous
39 - 970 Hz : 1000 ms / Off : 1000 ms
40 - 800 Hz : 150 ms / 970 Hz : 150 ms
41 - Sweep 2400 Hz - 2850 Hz over 110 ms (9 Hz)
42 - Sweep 2400 Hz - 2850 Hz over 330 ms (3 Hz)
43 - 2850 Hz : 1000 ms / Off : 1000 ms
44 - 2400 Hz : 150 ms / 2850 Hz : 150 ms
45 - (German) Whoop 1200 Hz - 500 Hz : 1000ms / Off : 10 ms
46 - 440 Hz : 600 ms / Off : 600 ms
47 - Whoop 500 Hz - 1200 Hz : 3750 ms / Off : 250 ms
48 - ISO8201 : 925 Hz, 628 Hz : 250 ms / Off 500 ms
49 - ISO8201 : Sweep 300 Hz - 1200 Hz : 500 ms / Off : 500 ms
50 - ISO8201 : Sweep 1200 Hz - 300 Hz : 500 ms / Off : 500 ms

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for BRE Global Ltd	Verifier	Date of Issue	Date of First Issue
P. Halligan	P Halligan	29 September 2022	29 September 2022

This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.

 © BRE Global Ltd, 2022

80018

LPCB®

Appendix to Certificate No: 164h-(cl-3) Issue: 01

Kentec Electronics Limited

51 - Whoop 500-1200 3500 ms / Off 500 ms
53 - Marine 1000Hz (1s on, 1s off)x7 + (7s on, 1s off)
54 - Whoop 1200 Hz – 500 Hz : 1000ms
55 - Ramp up 150 Hz – 1000 Hz : 10s. 1000 Hz 40s. Ramp down 1000 Hz – 150 Hz: 10s.
56 - 725 Hz Continuous
57 - 725 Hz : 700 ms / Off : 300 ms

Bases

KS-BASE-3T	Standard Base
KS-BASE-3T-SCI	Short Circuit Isolator Base
KS-BASE-WS-RED	Standard Base
KS BASE-4T	Standard Base

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for BRE Global Ltd	Verifier	Date of Issue	Date of First Issue
P. Halligan	P Halligan	29 September 2022	29 September 2022

This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).
To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.
BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com
LPCB is a Registered Trademark of the Building Research Establishment Ltd.

 © BRE Global Ltd, 2022

80018